

NFPA 70

National Electrical Code®

2002 Edition

Reference: 680.32 TIA 02-2 (NFPA 70)

Pursuant to Section 5 of the NFPA Regulations Governing Committee Projects, the National Fire Protection Association has issued the following Tentative Interim Amendment to NFPA 70, *National Electrical Code*®, 2002 edition. The TIA was processed by the National Electrical Code® Committee, and was issued by the Standards Council on April 3, 2003, with an effective date of April 23, 2003.

A Tentative Interim Amendment is tentative because it has not been processed through the entire standards-making procedures. It is interim because it is effective only between editions of the standard. A TIA automatically becomes a proposal of the proponent for the next edition of the standard; as such, it then is subject to all of the procedures of the standards-making process.

1. Revise section 680.32 to read as follows:

680.32 All electrical equipment, including power-supply cords, used with storable pools shall be protected by ground-fault circuit interrupters. Location of receptacles that provide power for storable water-pump motors or other loads directly related to the circulation and sanitation system shall be located at least 3.0 m (10ft.) from the inside walls of the pool. Other receptacles, shall be not less than 3.0 m (10ft.) from the inside walls of a pool.